JAN 27 2017

Alton Coal Development, LLC. DIVISION OF AIR QUALITY

Summary of PM₁₀ Data
Collected at Coal Hollow Mine, Utah
During the Fourth Quarter, 2016


Submitted to:

Utah Division of Environmental Quality Division of Air Quality 195 North 1950 West Salt Lake City, Utah Contact: Jon Black

Document Date: 01/27/2017 DAQ-2017-001752

Prepared by:

Alton Coal Development, LLC. 463 N 100W, Suite1 Cedar City, Utah 84721 Contact: Kirk Nicholes 435.867.5331



UTAH DEPARTMENT OF ENVIRONMENTAL QUALITY

JAN 27 2017

DIVISION OF AIR QUALITY

Page 1

Contents

PM₁₀ Data, 4th Quarter, 2016

1.0	Intr	oduction			2
2.0 S	ite Lo	ocation			2
3.0	AIR	QUALI	ΓΥ DATA SUMMARIES		4
4.0	DAT	CA DEC	OVERY AND QUALITY AS	SSLIDANCE	7
4.0					
	4.1		ecovery		
	4.2		Assurance		
		4.2.1	Precision of PM ₁₀ Measurem		
		4.2.2	Audit Results		
		4.2.3	Zero and Single Point Flow	Rate Checks	10
			List of	Tables	
Table	e I - S	ummary (of Measured PM ₁₀ Concentrate	ions (μg/m ³)	5
			of Measured PM ₁₀ Concentra		
			of Measured PM ₁₀ Concentra		
			of Measured PM ₁₀ Concentra		
			parterly and Monthly Wind Sp		
			ry of Data Recovery		
Table	eviii	III- Audii	Summary		9
			List of I	Figures	
Figur	e 1 - S	ite Location	on Map		3
Figur	e 2 - S	atellite Vi	ew of Monitoring Locations		4
			List of Ap	pendices	
APPI	ENDIX	A			
Wind	lrose				
APPI	ENDIX	В			
Listir	ng of P	M ₁₀ Conc	entrations (Data sheets for monit	or's on DVD)	
APPI	ENDIX	C			
Preci	sion ar	nd Single-l	Point Flow Rate Checks		
APPI	ENDIX	D			
Field	Data S	Sheets			
APPI	ENDIX	Ε			
Indep	enden	t PM ₁₀ Sar	mpler Performance Audit Report		
Alton	Coal D	evelopmer	t, LLC		January 24, 2017

1.0 INTRODUCTION

This report summarizes measurements of Particulate Matter less than 10 microns nominal aerodynamic diameter (PM_{10}) collected and processed by Alton Coal Development, LLC, (ACD) from the five monitoring stations located at the Coal Hollow Mine Facility in Alton, Utah. Monitoring for PM_{10} is a condition of the mines operating permit.

PM₁₀ monitoring at the site consists of five BGI PQ200 PM₁₀ monitors run by solar power. Figure 2 of this report shows the approximate locations of the monitoring locations. The BGI PQ200 monitors are EPA Reference Method monitors and are operated on the National Particulate 1-in-6 Monitoring Schedule. The data summarized herein covers the data collected during the fourth quarter of 2016.

2.0 SITE LOCATION


The Coal Hollow Mine is located in Kane County, Utah, approximately three miles southeast of the town of Alton, Utah. Figure I on the following page gives an overview of the site location. Specifically, the Coal Hollow Mine is located in Sections 19, 20, 29, and 30 of Township 39S, Range 5W; with an approximate facility location of:

Northing: 41401699 meters

Easting: 371534 meters

Universal Transverse Mercator (UTM) Datum NAD27, Zone 12

The three monitoring locations as depicted in Figure 2, are located in positions to collect both background and maximum PM10 concentrations. The background monitor has a manufactures serial #962, therefore this monitor will be referred as monitor 962A. The compliance monitor for the Coal Hollow Mine (CHM) has a manufactures serial #963, therefore this monitor will be referred as monitor 963B. The co-located monitor has a manufactures serial #964, therefore this monitor will be referred as monitor 964C. The background monitor coordinates are Northing: 4140856, Easting 373119, (UTM) Datum NAD27, Zone 12. The CHM compliance monitor and the co-located monitor coordinates are Northing: 4140396, Easting 371147, (UTM) Datum NAD27, Zone 12. The compliance monitor for the North Private Lease (NPL) has a manufactures serial #2366, therefore this monitor will be referred as monitor 2366D. The co-located monitor has a manufactures serial #2398, therefore this monitor will be referred as monitor 2398E. The NPL compliance monitor and the co-located monitor coordinates are Northing: 4141570, Easting 370928, (UTM) Datum NAD27, Zone 12.



Alton Coal Development, LLC PM₁₀ Data, 4th Quarter, 2016

January 24, 2017

Northern Boundary, Max. PM10

Background PM10 Monitor

Southeastern Corner Max. PM10 Impact Monitor

Existing Meterological Station.

Google earth

Figure 2 - Satellite View of Monitoring Locations

3.0 AIR QUALITY DATA SUMMARIES

A listing of the measured PM₁₀ concentrations for the quarter are presented in Appendix B (individual data sheets are provided on the enclosed disk in the PDF version of Appendix B) and Field Data Sheets generated during the collection of each sample are presented in Appendix D. Measurements were collected during a 24-hour periods and represent the average PM₁₀ concentration during the midnight to midnight data collection cycle. As required by the operating permit for the CHM, duplicate measurements were made with Sampler #963B (designated as a compliance monitor) and Sampler #964C (designated as a co-located sampler) to the extent possible. The quarterly mean PM₁₀ concentration and the comparison of measured concentrations to standards are based on measurements from the primary Sampler #963B. If a measurement from Sampler #963B was missing or invalid, the measurement from the secondary Sampler #964C would be used. Also, required by the operating permit for the NPL, duplicate measurements were made with Sampler #2366D (designated as a compliance monitor) and Sampler #2398E (designated as a co-located sampler) to the extent possible. The quarterly mean PM₁₀ concentration and the comparison of measured concentrations to standards are based on measurements from the primary Sampler #2366D. If a measurement from Sampler #2366D was missing or invalid, the measurement from the secondary Sampler #2398E would be used.

The highest 24-hour mean PM_{10} concentrations measured during the quarter from the three monitoring locations are summarized in Table I, Table II, Table III, Table IV and Table V. The three highest concentrations, # of valid samples, and the arithmetic mean concentrations from each of the sites are listed. All measured PM_{10} concentrations were below the 24-hour National Ambient Air Quality Standard (NAAQS) of 150 $\mu g/m^3$.

Table I - Summary of Measured PM_{10} Concentrations ($\mu g/m^3$) Background Monitor - 962A

RANK	DATE	PM ₁₀ CONCENTRATION
Highest	10/03/2016	12.2
2 nd Highest	10/15/2016	9.8
Monthly Mean	10/1/16-10/31/16	8.6
Monthly Mean	11/1/16-11/30/16	5.0
Monthly Mean	12/1/16-12/31/16	4.2
Quarterly Mean	10/1/16-12/31/16 (15 valid samples)	5.9

Table II - Summary of Measured PM_{10} Concentrations ($\mu g/m^3$) Compliance Monitor - 963B

RANK	DATE	PM ₁₀ CONCENTRATION
Highest	11/14/2016	111.5
2 nd Highest	12/20/2016	80.3
Monthly Mean	10/1/16-10/31/16	25.1
Monthly Mean	11/1/16-11/30/16	39.0
Monthly Mean	12/1/16-12/31/16	28.2
Quarterly Mean	10/1/16-12/31/16 (15 valid samples)	30.8

Table III - Summary of Measured PM_{10} Concentrations ($\mu g/m^3$) Collocated Monitor - 964C

RANK	DATE	PM ₁₀ CONCENTRATION
Highest	11/14/2016	109.6
2 nd Highest	12/20/2016	101.9
Monthly Mean	10/1/16-10/31/16	34.0
Monthly Mean	11/1/16-11/30/16	39.4
Monthly Mean	12/1/16-12/31/16	31.2
Quarterly Mean	10/1/16-12/31/16 (15 valid samples)	38.0

Table IV - Summary of Measured PM_{10} Concentrations ($\mu g/m^3$) Compliance Monitor -2366D

RANK	DATE	PM ₁₀ CONCENTRATION
Highest	10/21/2016	53.0
2 nd Highest	10/03/2016	50.0
Monthly Mean	10/1/16-10/31/16	35.0
Monthly Mean	11/1/16-11/30/16	13.1
Monthly Mean	12/1/16-12/31/16	20.7
Quarterly Mean	10/1/16-12/31/16 (14 valid samples)	23.6

Table V - Summary of Measured PM_{10} Concentrations ($\mu g/m^3$)

Collocated Monitor -2398E

RANK	DATE	PM ₁₀ CONCENTRATION
Highest	10/03/2016	61.5
2 nd Highest	10/21/2016	56.7
Monthly Mean	10/1/16-10/31/16	39.7
Monthly Mean	11/1/16-11/30/16	11.0
Monthly Mean	12/1/16-12/31/16	18.6
Quarterly Mean	10/1/16-12/31/16 (15 valid samples)	23.1

Table VI - Mean Quarterly and Monthly Wind Speed

	4th Quarter 2016	Oct.	Nov.	Dec.
Mean Wind Speed (m/s)	2.66	2.96	2.98	2.03

4.0 DATA RECOVERY AND QUALITY ASSURANCE

4.1 Data Recovery

Monitor 962A

Monitor 962A collected 15 of the 15 samples during the quarter. The percent recovery for this quarter is 100%.

Monitor 963B

Monitor 963B collected 15 of the 15 samples during the quarter. The percent recovery for this quarter is 100%.

Monitor 964C

Monitor 964C collected 15 of the 15 samples during the quarter. The percent recovery for this quarter is 100%.

Monitor 2366D

Monitor 2366D collected 14 of the 15 samples during the quarter. The percent recovery for this quarter is 93%. For the sample date of Nov 2nd, the monitor timer information indicates that the stop time was inaccurately programed, the run was halted by the operator at 53 hrs. of run time.

Monitor 2398E

Monitor 2398E collected 15 of the 15 samples during the quarter. The percent recovery for this quarter is 100%.

The PM₁₀ data recoveries for the five monitoring stations are presented below:

Table VIII - Summary of Data Recovery

SAMPLER	POSSIBLE SAMPLES	VALID SAMPLES	PERCENT DATA RECOVERY
962A	15	15	100%
963B	15	15	100%
964C	15	15	100%
2366D	15	14	93%
2398E	15	15	100%

4.2 Quality Assurance

Quality assurance procedures utilized to verify the integrity of the measured PM₁₀ data included the following:

- 1. Review of PM₁₀ precision measurements based upon duplicate, collocated measurements.
- 2. Independent quarterly audits of the PM₁₀ samplers.
- 3. Monthly zero and single point flow rate checks of the PM₁₀ samplers.

4.2.1 Precision of PM₁₀ Measurements

The precision of the PM₁₀ measurements was determined from the duplicate samples collected from the collocated BGI PQ200 Monitors 963B and 964C at the Coal Hollow Mine and 2366D and 2398E at the North Private Lease. As recommended in 40 CFR, Part 58, Appendix A, Section 5.3.1, PM₁₀ precision checks are reported for instances when the concentrations for duplicate samples both exceed 3 µg/m³. Duplicate samples that did not meet this condition were omitted for the purposes of the precision checks. Appendix C, of this report summarizes precision calculations between the compliance monitor and the co-located monitor. Monthly flow rate verification data is also summarized in Appendix C.

Precision calculations at the Coal Hollow Mine were developed based on 14 valid pairs of colocated monitoring data during the quarter. Single point precision based on 40 CFR, Part 58, Appendix A Equation 2 results were -59.8% to 16.4%. The aggregate coefficient of variability (CV) calculated in accordance with 40 CFR, Part 58, Appendix A Equation 11 is 20.51%. This value is not within the 10% goal for aggregate CV.

Precision calculations at the North Private Lease were developed based on 13 valid pairs of colocated monitoring data during the quarter. Single point precision based on 40 CFR, Part 58, Appendix A Equation 2 results were -24.2% to 32.4%. The aggregate coefficient of variability (CV) calculated in accordance with 40 CFR, Part 58, Appendix A Equation 11 is 15.44%. This value is not within the 10% goal for aggregate CV.

4.2.2 Audit Results

The accuracy of the PM₁₀ sampler flows was verified by a performance audit conducted by Air Resource Specialist on Nov. 9, 2016. A copy of the audit report is presented in Appendix E and is summarized in Table VI. The audit results indicate that the five samplers were operating properly.

Table VII III- Audit Summary

SAMPLER	AUDIT % DIFFERENCE	LIMIT*	DESIGN % DIFFERENCE	LIMIT*
962A	-1.5	±4%	1.5	± 5%

963B	0.1	±4%	-0.1	± 5%
964C	-0.5	±4%	0.5	± 5%
2366D	-0.3	±4%	0.3	± 5%
2398E	-0.4	±4%	0.4	± 5%


^{*}Values between \pm 7% and \pm 10% require recalibration but no data are invalidated.

4.2.3 Zero and Single Point Flow Rate Checks

Zero and single-point flow rate verifications are performed by a site technician on a monthly basis. The data was then input into a statistical calculator to calculate percent difference and bias between each of the monitors and the monthly single point flow rate measured by a NIST traceable calibration orifice. The calculator used is called the "Data Assessment Statistical Calculator" DASC Tool. DASC was developed for the data user community and can be found in the Precision and Accuracy Reporting System within the Quality Assurance section of EPA's Ambient Monitoring Technology Information System. This data is presented in Appendix C of this report.

APPENDIX A

Windrose



Start Date: 10/1/2016 - 00:00 End Date: 12/31/2016 - 23:00 Run ID:

Frequency Distribution (Count)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	21	19	53	28	0	0	121
11.25-33.75	82	45	6	4	0	0	137
33.75-56.25	115	361	88	0	0	0	564
56.25-78.75	61	30	0	0	0	0	91
78.75-101.25	38	9	6	2	0	0	55
101.25-123.75	30	33	26	13	0	0	102
123.75-146.25	46	41	18	6	0	0	111
146.25-168.75	37	44	35	0	0	0	116
168.75-191.25	36	65	33	12	0	0	146
191.25-213.75	41	72	49	1	0	0	163
213.75-236.25	17	67	68	14	0	0	166
236.25-258.75	15	11	16	0	0	0	42
258.75-281.25	14	11	4	3	0	0	32
281.25-303.75	18	11	0	0	0	0	29
303.75-326.25	27	21	11	6	0	0	65
326.25-348.75	27	24	40	11	0	0	102
Total	625	864	453	100	0	0	2208

Frequency of Calm Winds: 166 Average Wind Speed: 2.66 m/s


Start Date: 10/1/2016 - 00:00 End Date: 12/31/2016 - 23:00 Run ID:

Frequency Distribution (Normalized)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	0.009511	0.008605	0.024004	0.012681	0.000000	0.000000	0.054801
11.25-33.75	0.037138	0.020380	0.002717	0.001812	0.000000	0.000000	0.062047
33.75-56.25	0.052083	0.163496	0.039855	0.000000	0.000000	0.000000	0.255435
56.25-78.75	0.027627	0.013587	0.000000	0.000000	0.000000	0.000000	0.041214
78.75-101.25	0.017210	0.004076	0.002717	0.000906	0.000000	0.000000	0.024909
101.25-123.75	0.013587	0.014946	0.011775	0.005888	0.000000	0.000000	0.046196
123.75-146.25	0.020833	0.018569	0.008152	0.002717	0.000000	0.000000	0.050272
146.25-168.75	0.016757	0.019928	0.015851	0.000000	0.000000	0.000000	0.052536
168.75-191.25	0.016304	0.029438	0.014946	0.005435	0.000000	0.000000	0.066123
191.25-213.75	0.018569	0.032609	0.022192	0.000453	0.000000	0.000000	0.073822
213.75-236.25	0.007699	0.030344	0.030797	0.006341	0.000000	0.000000	0.075181
236.25-258.75	0.006793	0.004982	0.007246	0.000000	0.000000	0.000000	0.019022
258.75-281.25	0.006341	0.004982	0.001812	0.001359	0.000000	0.000000	0.014493
281.25-303.75	0.008152	0.004982	0.000000	0.000000	0.000000	0.000000	0.013134
303.75-326.25	0.012228	0.009511	0.004982	0.002717	0.000000	0.000000	0.029438
326.25-348.75	0.012228	0.010870	0.018116	0.004982	0.000000	0.000000	0.046196
Total	0.283062	0.391304	0.205163	0.045290	0.000000	0.000000	0.924819

Frequency of Calm Winds: 7.52% Average Wind Speed: 2.66 m/s



Start Date: 10/1/2016 - 00:00 End Date: 10/31/2016 - 23:00 Run ID:

Frequency Distribution (Count)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	6	7	3	1	0	0	17
11.25-33.75	20	13	0	0	0	0	33
33.75-56.25	31	107	49	0	0	0	187
56.25-78.75	16	10	0	0	0	0	26
78.75-101.25	15	4	0	0	0	0	19
101.25-123.75	12	20	11	0	0	0	43
123.75-146.25	17	24	11	0	0	0	52
146.25-168.75	22	31	16	0	0	0	69
168.75-191.25	10	25	25	12	0	0	72
191.25-213.75	14	37	28	1	0	0	80
213.75-236.25	1	28	41	9	0	0	79
236.25-258.75	2	4	12	0	0	0	18
258.75-281.25	3	1	0	3	0	0	7
281.25-303.75	5	2	0	0	0	0	7
303.75-326.25	6	6	2	0	0	0	14
326.25-348.75	5	6	8	0	0	0	19
Total	185	325	206	26	0	0	744

Frequency of Calm Winds: 2 Average Wind Speed: 2.96 m/s


Start Date: 10/1/2016 - 00:00 End Date: 10/31/2016 - 23:00 Run ID:

Frequency Distribution (Normalized)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	0.008065	0.009409	0.004032	0.001344	0.000000	0.000000	0.022849
11.25-33.75	0.026882	0.017473	0.000000	0.000000	0.000000	0.000000	0.044355
33.75-56.25	0.041667	0.143817	0.065860	0.000000	0.000000	0.000000	0.251344
56.25-78.75	0.021505	0.013441	0.000000	0.000000	0.000000	0.000000	0.034946
78.75-101.25	0.020161	0.005376	0.000000	0.000000	0.000000	0.000000	0.025538
101.25-123.75	0.016129	0.026882	0.014785	0.000000	0.000000	0.000000	0.057796
123.75-146.25	0.022849	0.032258	0.014785	0.000000	0.000000	0.000000	0.069892
146.25-168.75	0.029570	0.041667	0.021505	0.000000	0.000000	0.000000	0.092742
168.75-191.25	0.013441	0.033602	0.033602	0.016129	0.000000	0.000000	0.096774
191.25-213.75	0.018817	0.049731	0.037634	0.001344	0.000000	0.000000	0.107527
213.75-236.25	0.001344	0.037634	0.055108	0.012097	0.000000	0.000000	0.106183
236.25-258.75	0.002688	0.005376	0.016129	0.000000	0.000000	0.000000	0.024194
258.75-281.25	0.004032	0.001344	0.000000	0.004032	0.000000	0.000000	0.009409
281.25-303.75	0.006720	0.002688	0.000000	0.000000	0.000000	0.000000	0.009409
303.75-326.25	0.008065	0.008065	0.002688	0.000000	0.000000	0.000000	0.018817
326.25-348.75	0.006720	0.008065	0.010753	0.000000	0.000000	0.000000	0.025538
Total	0.248656	0.436828	0.276882	0.034946	0.000000	0.000000	0.997312

Frequency of Calm Winds: 0.27% Average Wind Speed: 2.96 m/s



Start Date: 11/1/2016 - 00:00 End Date: 11/30/2016 - 23:00 Run ID:

Frequency Distribution (Count)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	10	7	30	21	0	0	68
11.25-33.75	42	22	2	0	0	0	66
33.75-56.25	52	127	25	0	0	0	204
56.25-78.75	12	16	0	0	0	0	28
78.75-101.25	11	4	6	2	0	0	23
101.25-123.75	8	13	15	10	0	0	46
123.75-146.25	11	16	4	1	0	0	32
146.25-168.75	5	12	14	0	0	0	31
168.75-191.25	5	26	6	0	0	0	37
191.25-213.75	14	15	12	0	0	0	41
213.75-236.25	3	21	15	1	0	0	40
236.25-258.75	6	5	1	0	0	0	12
258.75-281.25	4	2	0	0	0	0	6
281.25-303.75	7	5	0	0	0	0	12
303.75-326.25	8	3	3	2	0	0	16
326.25-348.75	12	12	23	9	0	0	56
Total	210	306	156	46	0	0	720

Frequency of Calm Winds: 2 Average Wind Speed: 2.98 m/s


Start Date: 11/1/2016 - 00:00 End Date: 11/30/2016 - 23:00 Run ID:

Frequency Distribution (Normalized)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	0.013889	0.009722	0.041667	0.029167	0.000000	0.000000	0.094444
11.25-33.75	0.058333	0.030556	0.002778	0.000000	0.000000	0.000000	0.091667
33.75-56.25	0.072222	0.176389	0.034722	0.000000	0.000000	0.000000	0.283333
56.25-78.75	0.016667	0.022222	0.000000	0.000000	0.000000	0.000000	0.038889
78.75-101.25	0.015278	0.005556	0.008333	0.002778	0.000000	0.000000	0.031944
101.25-123.75	0.011111	0.018056	0.020833	0.013889	0.000000	0.000000	0.063889
123.75-146.25	0.015278	0.022222	0.005556	0.001389	0.000000	0.000000	0.044444
146.25-168.75	0.006944	0.016667	0.019444	0.000000	0.000000	0.000000	0.043056
168.75-191.25	0.006944	0.036111	0.008333	0.000000	0.000000	0.000000	0.051389
191.25-213.75	0.019444	0.020833	0.016667	0.000000	0.000000	0.000000	0.056944
213.75-236.25	0.004167	0.029167	0.020833	0.001389	0.000000	0.000000	0.055556
236.25-258.75	0.008333	0.006944	0.001389	0.000000	0.000000	0.000000	0.016667
258.75-281.25	0.005556	0.002778	0.000000	0.000000	0.000000	0.000000	0.008333
281.25-303.75	0.009722	0.006944	0.000000	0.000000	0.000000	0.000000	0.016667
303.75-326.25	0.011111	0.004167	0.004167	0.002778	0.000000	0.000000	0.022222
326.25-348.75	0.016667	0.016667	0.031944	0.012500	0.000000	0.000000	0.077778
Total	0.291667	0.425000	0.216667	0.063889	0.000000	0.000000	0.997222

Frequency of Calm Winds: 0.28% Average Wind Speed: 2.98 m/s



Start Date: 12/1/2016 - 00:00 End Date: 12/31/2016 - 23:00 Run ID:

Frequency Distribution (Count)

Wind Direction (Blowing From) / Wind Speed (m/s)

	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	5	5	20	6	0	0	36
11.25-33.75	20	10	4	4	0	0	38
33.75-56.25	32	127	14	0	0	0	173
56.25-78.75	33	4	0	0	0	0	37
78.75-101.25	12	1	0	0	0	0	13
101.25-123.75	10	0	0	3	0	0	13
123.75-146.25	18	1	3	5	0	0	27
146.25-168.75	10	1	5	0	0	0	16
168.75-191.25	21	14	2	0	0	0	37
191.25-213.75	13	20	9	0	0	0	42
213.75-236.25	13	18	12	4	0	0	47
236.25-258.75	7	2	3	0	0	0	12
258.75-281.25	7	8	4	0	0	0	19
281.25-303.75	6	4	0	0	0	0	10
303.75-326.25	13	12	6	4	0	0	35
326.25-348.75	10	6	9	2	0	0	27
Total	230	233	91	28	0	0	744

Frequency of Calm Winds: 162 Average Wind Speed: 2.03 m/s

Start Date: 12/1/2016 - 00:00 End Date: 12/31/2016 - 23:00 Run ID:

Frequency Distribution (Normalized)


Wind Direction (Blowing From) / Wind Speed (m/s)


	0.5 - 2.1	2.1 - 3.6	3.6 - 5.7	5.7 - 8.8	8.8 - 11.1	>= 11.1	Total
348.75-11.25	0.006720	0.006720	0.026882	0.008065	0.000000	0.000000	0.048387
11.25-33.75	0.026882	0.013441	0.005376	0.005376	0.000000	0.000000	0.051075
33.75-56.25	0.043011	0.170699	0.018817	0.000000	0.000000	0.000000	0.232527
56.25-78.75	0.044355	0.005376	0.000000	0.000000	0.000000	0.000000	0.049731
78.75-101.25	0.016129	0.001344	0.000000	0.000000	0.000000	0.000000	0.017473
101.25-123.75	0.013441	0.000000	0.000000	0.004032	0.000000	0.000000	0.017473
123.75-146.25	0.024194	0.001344	0.004032	0.006720	0.000000	0.000000	0.036290
146.25-168.75	0.013441	0.001344	0.006720	0.000000	0.000000	0.000000	0.021505
168.75-191.25	0.028226	0.018817	0.002688	0.000000	0.000000	0.000000	0.049731
191.25-213.75	0.017473	0.026882	0.012097	0.000000	0.000000	0.000000	0.056452
213.75-236.25	0.017473	0.024194	0.016129	0.005376	0.000000	0.000000	0.063172
236.25-258.75	0.009409	0.002688	0.004032	0.000000	0.000000	0.000000	0.016129
258.75-281.25	0.009409	0.010753	0.005376	0.000000	0.000000	0.000000	0.025538
281.25-303.75	0.008065	0.005376	0.000000	0.000000	0.000000	0.000000	0.013441
303.75-326.25	0.017473	0.016129	0.008065	0.005376	0.000000	0.000000	0.047043
326.25-348.75	0.013441	0.008065	0.012097	0.002688	0.000000	0.000000	0.036290
Total	0.309140	0.313172	0.122312	0.037634	0.000000	0.000000	0.782258

Frequency of Calm Winds: 21.77% Average Wind Speed: 2.03 m/s

APPENDIX B

Listing of PM₁₀ Concentrations






October 1, 2016 - December 31, 2016

Network: Alton Coal Development

Site: Coal Hollow

Sampler ID: Coal Hollow-A AQS ID:

	Filter	Concentration (µg/m3)	Concentration (µg/m3)	Sample Period	Sample Volume	Std Volume	Tare	Mass Gross	Net		
Date	ID	LTP	STP	(hr:min)	(m3)	(m3)	(mg)	(mg)	(mg)	Flag	Comments
10/03/16	P2933162	10.0	12.2	23:59	24.0	19.6	369.748	369.989	0.241		
10/09/16	P2933513	6.2	7.7	24:00	24.0	19.5	382.312	382.463	0.151		
10/15/16	P2933523	7.8	9.8	23:59	24.0	19.2	378.220	378.408	0.188		
10/21/16	P2933829	5.5	6.8	23:59	24.0	19.6	387.875	388.008	0.133		
10/27/16	P2933518	5.2	6.6	23:59	24.0	19.2	390.837	390.964	0.127	XT	
11/02/16	P2933830	3.2	3.8	23:59	24.0	19.8	374.041	374.118	0.077	HT	
11/08/16	P2933835	3.6	4.4	23:59	24.0	19.8	380.794	380.882	0.088		
11/14/16	P2934147	5.0	6.1	23:59	24.0	19.8	384.306	384.428	0.122		
11/20/16	P2934428	4.7	5.7	23:59	24.0	19.6	379.950	380.063	0.113		
11/26/16	P2934433	4.3	5.2	23:59	24.0	19.9	375.840	375.945	0.105		
12/02/16	P2934438	3.7	4.4	23:59	24.0	20.4	378.436	378.526	0.090		
12/08/16	P2934772	7.1	8.4	23:59	24.0	20.4	391.553	391.726	0.173		
12/14/16	P2934773	1.7	2.1	24:00	24.0	20.0	382.432	382.475	0.043		
12/20/16	P2935091	3.7	4.4	23:59	24.0	20.4	381.251	381.341	0.090		
12/26/16	P2935096	1.4	1.6	23:59	24.0	21.1	383.239	383.274	0.035	TD	
11/04/16	P2934146		Field Bla	nk			385.463	385.474	0.011		
	# Valid	Recovery	Average	St. Dev.	Max	Min					
	15	100%	5.9	2.8	12.2	1.6					



October 1, 2016 - December 31, 2016


Network: Alton Coal Development

Site: Coal Hollow

Sampler ID: Coal Hollow-B

AQS ID:

	Filter	Concentration (µg/m3)	Concentration (µg/m3)	Sample Period	Sample Volume	Std Volume	Tare	Mass Gross	Net		
Date	ID	LTP	\$TP	(hr:min)	(m3)	(m3)	(mg)	(mg)	(mg)	Flag	Comments
10/03/16	P2933164	16.6	20.2	23:59	24.0	19.8	373.655		0.401		
10/09/16	P2933514	6.6	8.1	24:00	24.0	19.7	375.880	376.040	0.160		
10/15/16	P2933524	6.4	8.0	23:59	24.0	19.3	379.486	379.641	0.155		
10/21/16	P2933827	46.7	56.7	23:59	24.0	19.8	383.659	384.783	1.124		Smudged; discoloration
10/27/16	P2933519	26.6	32.6	23:59	24.0	19.7	388.245	388.886	0.641	XT	
11/02/16	P2933831	15.3	18.4	23:59	24.0	20.0	385.662	386.031	0.369	HT	
11/08/16	P2934142	44.5	53.5	23:59	24.0	20.0	389.341	390.412	1.071		
11/14/16	P2934149	92.6	111.5	23:59	24.0	20.0	391.473	393.699	2.226		
11/20/16	P2934429	5.5	6.6	23:59	24.0	19.9	385.179	385.312	0.133		
11/26/16	P2934434	4.4	5.2	23:59	24.0	20.2	378.095	378.202	0.107		
12/02/16	P2934439	18.1	21.1	23:59	24.0	20.6	374.876	375.312	0.436		Lighter color
12/08/16	P2934778	25.6	29.9	23:59	24.0	20.6	374.649	375.266	0.617		Discoloration
12/14/16	P2934783	5.2	6.2	23:59	24.0	20.2	385.377	385.504	0.127		
12/20/16	P2935092	69.0	80.3	23:59	24.0	20.7	390.654	392.314	1.660		Smudges
12/26/16	P2935097	3.3	3.7	23:59	24.0	21.4	384.978	385.059	0.081	PI	
	# Valid	Recovery	Average	St. Dev.	Max	Min					
	15	100%	30.8	31.8	111.5	3.7					



October 1, 2016 - December 31, 2016


Network: Alton Coal Development

Site: Coal Hollow

Sampler ID: Coal Hollow-C

AQS ID:

	Filter	Concentration (µg/m3)	Concentration (µg/m3)	Sample Period	Sample Volume	Std Volume		Mass Gross	Net		
Date	ID	LTP	STP	(hr:min)	(m3)	(m3)	(mg)	(mg)	(mg)	Flag	Comments
10/03/16	P2933165	18.0	21.9	23:59	24.0	19.8	365.099	365.534	0.435		
10/09/16	P2933515	6.5	8.0	24:00	24.0	19.7	389.034	389.192	0.158		
10/15/16	P2933525	9.0	11.2	23:59	24.0	19.4	385.936	386.154	0.218		
10/21/16	P2933828	78.4	94.9	23:59	24.0	19.9	385.604	387.491	1.887		Smudged; discoloration
10/27/16	P2933520	28.0	34.1	23:59	24.0	19.7	379.666	380.340	0.674	XT	
11/02/16	P2933832	19.5	23.4	23:59	24.0	20.0	380.241	380.710	0.469	HT	
11/08/16	P2934143	43.2	51.8	23:59	24.0	20.0	386.573	387.612	1.039		
11/14/16	P2934148	91.3	109.6	23:59	24.0	20.0	372.675	374.869	2.194		
11/20/16	P2934430	4.7	5.6	23:59	24.0	20.0	384.949	385.063	0.114		
11/26/16	P2934435	5.6	6.7	23:59	24.0	20.3	376.199	376.335	0.136		
12/02/16	P2934440	33.6	39.1	23:59	24.0	20.7	377.573	378.383	0.810		Discoloration; darker
12/08/16	P2934780	33.0	38.4	23:59	24.0	20.7	373.670	374.465	0.795		Discoloration
12/14/16	P2934774	6.7	8.0	23:59	24.0	20.2	381.406	381.569	0.163		
12/20/16	P2935093	87.8	101.9	23:59	24.0	20.7	375.324	377.436	2.112		Smudged; loose particles
12/26/16	P2935098	2.5	2.8	23:59	24.0	21.5	381.329	381.390	0.061		
11/09/16	P2933824		Field Bla	nk			378.594	378.602	0.008		
12/05/16	P2934779		Field Bla	nk			381.590	381.599	0.009		
	# Valid	Recovery	Average	St. Dev.	Max	Min					
	15	100%	37.2	36.7	109.6	2.8					



October 1, 2016 - December 31, 2016

Network: Alton Coal Development

Site: Coal Hollow

Sampler ID: Coal Hollow-D AQS ID:

	Filter	Concentration (µg/m3)	Concentration (µg/m3)	Sample Period	Sample Volume	Std Volume	Tare	Mass Gross	Net		
Date	ID	LTP	STP.	(hr:min)	(m3)	(m3)	(mg)	(mg)	(mg)	Flag	Comments
10/03/16	P2933166	41.1	50.0	23:59	24.0	19.8	368.570	369.560	0.990		
10/09/16	P2933516	6.8	8.3	24:00	24.0	19.7	380.858	381.023	0.165		
10/15/16	P2933526	27.2	33.8	23:59	24.0	19.3	381.564	382.218	0.654		
10/21/16	P2933825	43.5	53.0	23:59	24.0	19.8	383.675	384.722	1.047		
10/27/16	P2933521	24.5	29.9	23:59	24.0	19.7	377.400	377.991	0.591	XT	
11/02/16	P2933833	Invalid - AG	Invalid - AG	57:34	57.7	47.9	380.530	380.882	0.352	SP,CI,HT	
11/08/16	P2934144	13.6	16.4	23:59	24.0	20.0	391.246	391.575	0.329		
11/14/16	P2934150	18.6	22.4	23:59	24.0	19.9	381.324	381.771	0.447		
11/20/16	P2934431	6.2	7.5	23:59	24.0	20.0	390.857	391.007	0.150		
11/26/16	P2934436	5.0	6.0	23:59	24.0	20.2	369.731	369.853	0.122		
12/02/16	P2934441	4.5	5.2	23:59	24.0	20.7	381.103	381.212	0.109		
12/08/16	P2934781	22.5	26.2	23:59	24.0	20.6	380.576	381.118	0.542		Darker color
12/14/16	P2934775	25.3	30.0	23:59	24.0	20.2	374.763	375.372	0.609	PI	
12/20/16	P2935094	34.8	40.6	23:59	24.0	20.6	385.229	386.066	0.837		
12/26/16	P2935100	1.4	1.6	23:59	24.0	21.5	379.340	379.375	0.035	PI,TD	
12/22/16	P2935099		Field Bla	nk			384.479	384.513	0.034	FBout	Dark hair
	# Valid	Recovery	Average	St. Dev.	Max	Min					
	14	93%	23.6	16.9	53.0	1.6					

Collocated Monitor 2398E

October 1, 2016 - December 31, 2016

Network: Alton Coal Development

Site: Coal Hollow

Sampler ID: Coal Hollow-E AQS ID:


	Filter	Concentration (µg/m3)	Concentration (µg/m3)	Sample Period	Sample Volume	Std Volume	Tare	Mass Gross	Net		
Date	ID	LTP	STP	(hr:min)	(m3)	(m3)	(mg)	(mg)	(mg)	Flag	Comments
10/03/16	P2933167	50.6	61.5	23:59	24.0	19.8	364.482	365.700	1.218		
10/09/16	P2933517	7.3	9.0	24:00	24.0	19.6	381.201	381.378	0.177		
10/15/16	P2933527	34.6	43.1	23:59	24.0	19.3	378.992	379.825	0.833		
10/21/16	P2933826	46.6	56.7	23:59	24.0	19.8	378.726	379.848	1.122		
10/27/16	P2933522	23.3	28.4	23:59	24.0	19.7	376.622	377.184	0.562	XT	
11/02/16	P2933834	5.1	6.2	23:59	24.0	20.0	382.533	382.657	0.124	HT	
11/08/16	P2934145	12.1	14.5	23:59	24.0	20.0	384.806	385.097	0.291		
11/14/16	P2934151	17.7	21.4	23:59	24.0	19.9	382.999	383.426	0.427		
11/20/16	P2934432	6.2	7.5	23:59	24.0	20.0	379.386	379.536	0.150		
11/26/16	P2934437	4.5	5.4	23:59	24.0	20.1	381.107	381.217	0.110		
12/02/16	P2934442	5.5	6.4	23:59	24.0	20.6	379.188	379.321	0.133		
12/08/16	P2934782	16.1	18.9	23:59	24.0	20.6	377.924	378.313	0.389		Lighter color
12/14/16	P2934776	24.4	29.0	23:59	24.0	20.2	381.341	381.928	0.587	PI	
12/20/16	P2935095	31.7	37.0	23:59	24.0	20.6	383.937	384.700	0.763		
12/26/16	P2935101	1.3	1.5	23:59	24.0	21.4	378.041	378.074	0.033		
12/05/16	P2934777		Field Bla	nk			376.619	376.625	0.006		
	# Valid	Recovery	Average	St. Dev.	Max	Min					
	15	100%	23.1	19.2	61.5	1.5					

APPENDIX C

Precision and Single-Point Flow Rate Checks


Precision Estimate (From Collocated Samples)

Monitors 963B &	964C	Pollutant typ	e:				CV	_{ub} (%)		
Meas Val (Y) 20.2	Audit Val (X) 21.9	d (Eqn 10) -8.1	25th Percentile -25.317	d ² 65.222	 d 8.076	d ² 65.222				
8.1 8	8 11.2		75th Percentile -0.193	1.543 1111.111	1.242 33.333	1.543 1111.111		Σ d 301.773	$\Sigma \mathbf{d} ^2$ 10628.389	
56.7 32.6	94.9 34.1			2539.734 20.230	50.396 4.498	2539.734 20.230		∑ d -256.606	Σd^2 10628.389	
18.4 53.5 111.5	23.4 51.8 109.6	3.2		572.331 10.426 2.953859	23.923 3.229 1.719	572.331 10.426 2.954				
6.6 5.2	5.6 6.7			268.745 635.5483	16.393 25.210	268.745 635.548	CV	(%) (Eqn 11) 20.51		
21.1 29.9	39.1 38.4	-24.9		3576.119 619.522	59.801 24.890	3576.119 619.522				
6.2 80.3	101.9			642.730 562.174	25.352 23.710	642.730 562.174				




	ıs (%)	Bia				e:	Pollutant typ	962A	Site ID: Monitor
			d ²	d	d ²	25th Percentile	d (Eqn. 1)	Audit Val (X)	Meas Val (Y)
			1.401	1.183	1.401	-1.764	-1.183	16.9	16.7
"AB" (Eqn 4)	$\sum \mathbf{d} $	n	2.175	1.475	2.175	75th Percentile	-1.475	16.95	16.7
1.570	4.711	3	4.214	2.053	4.214	-1.329	-2.053	17.05	16.7
"AS" (Eqn 5)	$\Sigma \mathbf{d} ^2$	1-1	l,						
0.442	7.790	2							

Bias (%) (Eqn 3)	Both Signs Positive
2.32	FALSE
Signed Bias (%)	Both Signs Negative
-2.32	TRUE




	as (%)	Bia				e:	Pollutant typ	963B	Site ID: Monitor 963B		
			d ²	d	d ²	25th Percentile	d (Eqn. 1)	Audit Val (X)	Meas Val (Y)		
			0.354	0.595	0.354	-0.801	-0.595	16.8	16.7		
"AB" (Eqn 4)	$\Sigma \mathbf{d} $	n	0.014	0.120	0.014	75th Percentile	0.120	16.68	16.7		
0.5	1.723	3	1.015	1.008	1.015	-0.238	-1.008	16.87	16.7		
"AS" (Eqn 5)	$\Sigma \mathbf{d} ^2$	n-1									
0.4	1.384	2									

Bias (%) (Eqn 3)	Both Signs Positive
1.32	FALSE
Signed Bias (%)	Both Signs Negative
-1.32	TRUE




Site ID: Monitor	964C	Pollutant type:					В	ias (%)	
Meas Val (Y)	Audit Val (X)	d (Eqn. 1)	25th Percentile	d^2	d	$ \mathbf{d} ^2$			
16.7	16.72	-0.120	-0.772	0.014	0.120	0.014			
16.7	16.78	-0.477	75th Percentile	0.227	0.477	0.227	n	$\sum \mathbf{d} $	"AB" (Eqn 4)
16.7	16.88	-1.066	-0.298	1.137	1.066	1.137	3	1.663	0.554
							n-1	$\Sigma \mathbf{d} ^2$	"AS" (Eqn 5)
							2	1.379	0.478

Bias (%) (Eqn 3)	Both Signs Positive
1.36	
Signed Bias (%)	Both Signs Negative
-1.36	TRUE





Precision Estimate (From Collocated Samples)

Monitors 963D &	964E	Pollutant type:					CV _{ub} (%)	
Meas Val (Y)	Audit Val (X)	d (Eqn 10)	25th Percentile	d²	[d]	d ²		
50	61.5	-20.6	-8.092	425.506	20.628	425.506		
8.3	9	-8.1	75th Percentile	65.488	8.092	65.488	n Σ d	$\Sigma \mathbf{d} ^2$
33.8	43.1	-24.2	9.278	585.023	24.187	585.023		3004.509
53	56.7	-6.7		45.504	6.746	45.504 n	-1 ∑d	Σd^2
29.9	28.4	5.1		26.479	5.146	26.479	12 -2.766	3004.509
16.4	14.5	12.3		151.234	12.298	151.234		
22.4	21.4	4.6		20.850	4.566	20.850		
7.5	7.5	0.0		0	0.000	0.000		
6	5.4	10.5		110.803	10.526	110.803	CV (%) (Eqn 11)	
5.2	6.4	-20.7		428.0618	20.690	428.062	15.44	
26.2	18.9	32.4		1047.979	32.373	1047.979	2 -3	
30	29	3.4		11.491	3.390	11.491		
40.6	37	9.3		86.088	9.278	86.088		





Site ID: Monitor	2366D	Pollutant typ	e:				Bi	as (%)	
Meas Val (Y)	Audit Val (X)	d (Eqn. 1)	25th Percentile	d ²	d	d ²			
16.7	16.69	0.060	-0.476	0.004	0.060	0.004			
16.7	16.75	-0.299	75th Percentile	0.089	0.299	0.089	n	$\sum \mathbf{d} $	"AB" (Eqn 4)
16.7	16.81	-0.654	-0.119	0.428	0.654	0.428	3	1.013	0.338
							n-1	$\sum \mathbf{d} ^2$	"AS" (Eqn 5)
						- 1	2	0.521	0.299





Site ID: Monitor	2398E	Pollutant typ	e:				Bi	ias (%)	
Meas Val (Y)	Audit Val (X)	d (Eqn. 1)	25th Percentile	d^2	d	$ \mathbf{d} ^2$			3.20
16.7	16.83	-0.772	-0.565	0.597	0.772	0.597			
16.7	16.76	-0.358	75th Percentile	0.128	0.358	0.128	n	$\sum \mathbf{d} $	"AB" (Eqn 4)
16.7	16.7	0.000	-0.179	0.000	0.000	0.000	3	1.130	0.377
							n-1	$\sum \mathbf{d} ^2$	"AS" (Eqn 5)
						- 1	2	0.725	0.387





APPENDIX D

Field Data Sheets

Background Monitor 962A

Table I - Every 6th Day Sampling

Time	Displayed Date	Displayed Time	Collected Filter ID#	New Filter ID#	Sample Start Time	Sample Start Date	Sampler Initials
1458	10-04-16	1356	36	4	M-M	10-09-16	UKSR
0933	10-11-16		4	9	M-M	10-15-16	UKSP
1719			9	16	M-M		KN
		0807	18	37		10-27	KAI
1133		1032	37	17	M-M	11-02-16	
1013	11-04-16	0911	17	28	M-M		
1015	11-04-16	0913	28	22	M-M		
617	11-09-16	1015	22	31	M-M	11-14-16	Kal
	11-16-16	1003	31	4	M-M	11-20-16	KNI
1137	11-23-16		4	9	4-11		
1459	11-29-16	1457	9	15	M-M	12-02-16	
1205	12-5.16	12:03	15	10	M-M	12.08.16	KN
0837	12.09.16	0837	10	17	m-m	12-14-16	KN
12:55	12-15-16	12:54	17	3/	m-m	12-20-1	KNI
1316	12.2416	1315	31	36	M-M	12-26-16	JKSR
1002	12-28-16		36	9	M-M	01-01-13	JKSR
1		4 <u>11.</u>					
Tal.							
A 1			1 11				
	1458 0933 1719 0909 1133 1015 1015 1017 1004 1137 1459 1205 0837 12:55 1316	11me Date 1458 M-04-16 0933 10-11-16 1719 10-18-16 1013 11-04-16 1015 11-04-16 1017 11-04-16 1017 11-23-16 1459 11-23-16 1205 12-5-16 0837 12-09-16 1316 12-23-16	Date Time	Date Time Filter ID#	Date Time Filter ID# ID#	Time Displayed Displayed Time Filter ID# Start Time 458	Time Displayed Displayed Collected New Filter ID# Start Time Start Date 1458

Blank

Cook F

Table II - Monthly Leak Test

. 45.0 1.	1110111111	, ====::	00.			
		Initial SP	Final SP	_1 2		
Date	Time	Value	Value	Pass/Fail	Initials	Maintenance
10/6/16	10:58	98	99	7-25	KN	Cleard Manifold
11/9/16		99	96	Pass	KN	
12/9/16	0908	99	96	Pass	KN	Cleaned Marifeld, applied Varcon gor
. ,				-		

Date	Time	Monitor Flow (Q Lpm)	Monitor Baro Pressure (mmHg)	Delta Cal Baro Pressure (mmHg)	Monitor Temp (A)	Delta Cal Temp (Ta)	Delta Cal Flow (Qs)	Delta Cal Flow (Qa)	Accuracy	Initials
10/6/16	1108	16.78	585	586	10.2	11.0	13,68	16.90	71.18	KN
1/19/16		16.70	5910	59/15	14,2	14.0		1695	-1.48	KN
12/9/88	0813	16.70	5F7	588	B1.8	2.9	14.20	11.05	-2.05	KN
7 7			Land in							

Compliance Monitor 963B

Table I - Every 6th Day Sampling

				NAME OF TAXABLE PARTY.					
Date	Time	Displayed Date	Displayed Time	Collected Filter ID#	New Filter ID#	Sample Start Time	Sample Start Date	Sampler Initials	
10-04-16	1514	10-04-16	1414	JBR1	5	11-11	10-07-16	JKSK	
10-11-16	1015	10-11-16	1914	5	14	M-M	10-15-16		
10-18-16	1703	10-18-16	1603	14	13	M-m	10-21-16	KN!	Ì
10-24-16	1203	10-24-16	1129	13	X B	M-M	10-28-16		
10-28-16	1151	10-28-16		38	18	U-M	11-02-16		
11-04-16	1031	11-04-16	0930	18	23	M-M	11-08-16		2
11-09-16	1055	11.09.16	1055	23	33	M-M	11-1946	KN	1
11-16-16	1326	11-16-16	13:26	27	5	M-M	11 -2016	KN	
11-23-16	1153	11-23-16	1152	5	//	4-11	11-26-16		
11-29-16	1512	11-29-16	1510	11	16	4-11	12-02-16	JKSF	
12-5-16	1230	12-5-16	12:29	16	22	M-m	12-08-16	KN	
12-9-16	0946	12-9-16	0946	27	28	M-M	12-14-16	KN	
12-15-16	13/4	12-15-16	1314	28	32	M-M	12-20-16	KNI	
12-24- 16	1229	12-29-16	1328	32	37	M-M	12-26-16	KSR	
12-28-16		12-28-16		37	10	M-M	01-01-17	UKSR	-
							1 2		
	. "							u I	
								1	
		= =							-

Black Backfilling Robinson

CODE P

Table II - Monthly Leak Test

		Initial SP	Final SP			7
Date	Time	Value	Value	Pass/Fail	Initials	Maintenance
10-6-16	1142	1095	92	Pass	KN	Cleand Manifold ad; F. Vtyllieght
11-9-16		105	102	Pass	KN	, ,
1209-16	0941	100	96	Pass	KN	Clear Manfild uccountresse
		4,1				7

		.,								
Date	Time	Monitor Flow (Q Lpm)	Monitor Baro Pressure (mmHg)	Delta Cal Baro Pressure (mmHg)	Monitor Temp (A)	Delta Cal Temp (Ta)	Delta Cal Flow (Qs)	Delta Cal Flow (Qa)	Accuracy	Initials
10-6-16	1201	16.7	592	592,5	11.8	12.8	13.65	1680	- 0: EO	KN
11-9-16		16.7	599	597.5	153	14.7		1608	0.12	KN
12-9-16	0945	16.7	598	5905	2.0	2,6	14,21	16.87	-1.01	KN
								1		

Co-located Monitor 964C

Table I - Every 6th Day Sampling

		The state of the s			_		-		•
Date	Time	Displayed Date	Displayed Time	Collected Filter ID#	New Filter ID#	Sample Start Time	Sample Start Date	Sampler Initials	
10-04-16	1515	10-04-16		JBR 7	6	11-11	10-09-16	UKSR	
10-11-16	1017	10-11-16	0913	6	25	M-M	10-15-16	VICSR	-
10-18-16	1657	10-18-16	1557	25	15	MM	10-2146	KN	
10-24-16	1236	10-24-16	1132	15	79	M-M	10-27-16	KNI	
10-28-16	1153	10-28-16		39	19		11-02-16	UKSR	21. 11. 1 21
11-04-16	1032	11-04-16	0937	19	24	M-M	11-08-16	JKSP	Black Working on Robertson
11-09-16	1048	10-09-16	1043	24	10	1045	11-09-16	KN	Blank
11-09-16	10:43	11.0816	12:43	10	32	M-an	11-14-16	KU	
11-16-16	1332	11-16-16		32	6	M-M	11-2048		
11-23-16	1154	11-23-16	1149	6	12	4-11	11-26-16	JKSR	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1
11-29-16	1514	1429-16	1508	6	25	4-11	12-02-16	JKSR	
12-05-16	12:30	12-05-16	1231	25	23	12:38	12-05-16	KN	Blank
12-08-16	12133	12-6546	1233	23	24	M-M	12-08-16	KN	
12-09-16	10:04	12-09-16	1004	29	18	M-M	12-14-16	KN	
12-15-16	1320	12-15-16	1314	18	33	M-M	12-20-16		
12-29-16	1330	12.27-16		33	38	14-16	12-26-16	JKSR	
12-28-16	1023	12-28-16	1017	38	11	11-11	01-01-17	JK5/	

Table II - Monthly Leak Test

		Initial SP	Final SP			
Date	Time	Value	Value	Pass/Fail	Initials	Maintenance
10/1/16	12:02	95	92	7055	KAL	Cleaned Manifold
11/9/16		100	96	Pass	KN	
12/9/16	0957	105	103	Pass	KN	cleand Markeld, uncomingress

		,								
Date	Time	Monitor Flow (Q Lpm)	Monitor Baro Pressure (mmHg)	Delta Cal Baro Pressure (mmHg)	Monitor Temp (A)	Delta Cal Temp (Ta)	Delta Cal Flow (Qs)	Delta Cal Flow (Qa)	Accuracy	Initials
10/6/16	PED	10.	593	5925	12.1	12.7	13.59	16.72	-0112	KN
11/9/16		16:70	597	597,5	14.6	14.5		16.78	-0.48	KN
12/09/16	1001	16.76	596	595	2,5	33	19,29	16,88	-1.07	KN
. ,										

Compliance Monitor 2366D

Table I - Every 6th Day Sampling

Date	Time	Displayed Date	Displayed Time	Collected Filter ID#	New Filter ID#	Sample Start Time	Sample Start Date	Sampler Initials
10-04-16	1528	10-04-16	1423	JBR 8	7	11-11	10-07-16	JKSK
10-11-16	1033	10-11-16	0928	7	29	M-M	10-15-16	UKSR
10-18-16	16:37	10-18-16	15:31	29	11	m-M	10-21-18	KN
10-24-16	17.55	10-24-16	1349	11	40	MA-NA		
10-28-16	1205	10-28-16	1059	40	20	M-M	11-02-16	UKSR
11-04-16	1044	11-04-16	0938	20	26	M-M	11-08-16	JKSR
11.09.16	1/3/	11-09-16	1125	26	34	M-M	11-14-16	KN
11-16-18	1248	11.1676	1342	34	7	M·M	11-20-18	KN
11-23-16	1205	11-23-16	1158	7	13	M-11	11.26.16	JKSP
11-29-16	1526	11-29-16	1519	13	29	M-M	12-02-16	JKSR
12-05-16	1256	12.05-16	1249	29	26	M-M	12-08-16	KN
12-09-16	1059	12.09.16	1059	26	19	m·m	12-14-16	KN
12-15-16	1441	12-15-16	1400	19	34	M-m	12-15-16	KN
12-28-16	1342	12-Zn-16	1349	34	39 864	1341	12-21-16	JKSR
12-21-16	13 45	12-22-16		39 866	40	M-M	12-26-16	JKSR
12-28-16	1037	12-28-16	1035	40	12	14-M	01-01-17	
	1							
		1						
1							3	
					1000000			The same of the sa

Chamber Oyon Blank

CODES - P,F

Table II - Monthly Leak Test

		Initial SP	Final SP			
Date	Time	Value	Value	Pass/Fail	Initials	Maintenance
10/6/18	1330	105	104	Pass	KN	cleaned Manifold
11/9/14		99	97	Pass	KN	
12/09/16	1106	94	92	Pass	KN	1 leaned Manifold, vac. greese souls
, ,	100 and 100 an		·			

Tubic III	141011111	13 1 10 11 1	tate ven	noauon						
Date	Time	Monitor Flow (Q Lpm)	Monitor Baro Pressure (mmHg)	Delta Cal Baro Pressure (mmHg)	Monitor Temp (A)	Delta Cal Temp (Ta)	Delta Cal Flow (Qs)	Delta Cal Flow (Qa)	Accuracy	Initials
10/6/16	1333	16.7	591	592	13.3	14.1	13.48	16.69	-0,06	KN
11/9/16	,	16.7	595	596,5	17.3	16,1		16.75	-0:30	KN
12/9/16	1110	16.70	594	594	500	6.4	1902	16.81	-0.65	KN
				1						

Co-located Monitor 2398E

Table I - Every 6th Day Sampling

Date	Time	Displayed Date	Displayed Time	Collected Filter ID#	New Filter ID#	Sample Start Time	Sample Start Date	Sampler Initials
10-04-16	15 30	10-04-16	1424	JBR 1	8	M-M	10-09-16	JKSR
10-11-16	1035	10-11-16	0929	8	30	M-M	10-15-16	NKSR
10-18-16	1641	10-18-16	1525	30	12	M-M	10-21-16	KN
10-24-16	1359	10-24-16		12	41	M-M	10-27-16	KN
10-28-16	1206	10-28-16	1059	41	21	M-M	11-02-16	JKSR
11-04-16	1046	11-04-16	6939	21	27	M-M	11-08-16	JICSR
11-09-16	1148	11.09.16	1/4/	27	35	M-M	11-181-16	KN
11-16-16	1354	11-16-16	1246	25	8	M-M	11-20-16	KN
11-23-16	1207		1159	8	14	M-M	11-26-16	JKSR
11-29-16	1528	11-29-16	1519	14	30	MM	12-02-16	JKSR
12-05-16	13 03	17-05-16	1255	28	27	M-M	12-08-18	KN
12-11-16	BEP .	+2 00 //	4	- dute-	=	A	-	T
12-09-16	1117	1209	1116	27	21	11:18	12/9/16	KN
12-09-16	1126	12-09-16	1126	21	20	M-M	12/14/16	KA
12-15-16	1446	12-15-16	1444	20	35	m-m	12/20/16	KN
12. ZE 16	1346	12-27-16	1344	35	41	Shi -M	12-21-16	JESR
12-28-16	1038	12-28-16	1036	41	13	M-M	01-01-17	JKSR
-		4						

Table II - Monthly Leak Test

		Initial SP	Final SP	,		
Date	Time	Value	Value	Pass/Fail	Initials	Maintenance
1016/16	1337	95	90	Pass	KAI	Cleaned Manifold
11/9/18		98 %		Fail	KN	adiated Tiller Coriar height
C	ATTE	23	25	2	A STATE OF THE PARTY OF THE PAR	colerad Al All in the processes
12/09/16	1120	183	106	PASS	KNI	Cleaned Manifold, arease

Blank

Date	Time	Monitor Flow (Q Lpm)	Monitor Baro Pressure (mmHg)	Delta Cal Baro Pressure (mmHg)	Monitor Temp (A)	Delta Cal Temp (Ta)	Delta Cal Flow (Qs)	Delta Cal Flow (Qa)	Accuracy	Initials
10/6/16	1340	16,20	591	-67	1112	1110	/2			
10/0//0	12 10	10:20	371	592	14,2	14.9	15,51	16.83	-0177	KN
119116	12 10	1670	597	596,5	15,9	16.0	13,57	16.83	-0,77	KN
119/16	12 10						13,51		-0.77	KN

APPENDIX E

Independent PM₁₀ Sampler Performance Audit Report

AUDIT REPORT FOR

ALTON COAL DEVELOPMENT, LLC COAL HOLLOW MINE ALTON, UTAH FOURTH QUARTER 2016

Prepared for

Kirk Nicholes Alton Coal Development, LLC 463 N 100 W Cedar City, Utah, 84721

Prepared by



1901 Sharp Point Drive, Suite E Fort Collins, CO 80525 970-484-7941

Site Audited: November 9, 2016

TABLE OF CONTENTS

Sectio	<u>n</u>	Page
1.0	INTRODUCTION	1-1
2.0	AUDIT METHODS AND EQUIPMENT 2.1 Particulate Samplers 2.2 Meteorological Parameters	2-1 2-1 2-2
3.0	AUDIT RESULTS	3-1
APPE	NDIX A Audit Data Forms	A-1
APPE	NDIX B Audit Standards Certifications	B-1
	LIST OF TABLES	
Table		Page
1-1	Site Location Information	1-1
1-2	Summary of Particulate Audit Results	1-1
1-3	Summary of Meteorological Audit Results	1-1
2-1	Particulate Samplers, Audit Methods and Acceptance Criteria	2-1
2-2	Particulate Samplers, Audit Equipment	2-2
2-3	Meteorological Sensors, Audit Ranges and Acceptance Criteri	ia 2-3
2-4	Meteorological Equipment	2-4

1.0 INTRODUCTION

Air Resource Specialists, Inc. (ARS) conducted a performance audit of Alton Coal Development, LLC ambient air quality monitoring systems on November 9, 2016. The monitoring sites are located at the Coal Hollow Mine near Alton, Utah.

Table 1-1
Site Location Information

	Primary CHM	Background	Primary NPL	Meteorological
Latitude	37° 24' 5.0" N	37° 24' 20.9" N	37° 24' 43" N	37° 23' 53.2" N
Longitude	112° 27' 21.0" W	112° 26' 1.1" W	112° 27' 30.6" W	112° 26' 43.1" W
UTM	12S 371147	12S 373119	12S 370928	12S 372073
	4140396	4140856	4141570	4140018
Elevation	6,890 feet MSL	7,158 feet MSL	6,959 feet MSL	7,007 feet MSL

Audit results for the particulate samplers are summarized in Table 1-2. Audit results for the meteorological measurements are summarized in Table 1-3. Detailed discussions of performance audit findings and other findings can be found in Section 3.0.

Table 1-2
Summary of Particulate Sampler Audit Results

	Parameter	Instrument	Within Accuracy Goal
Primary CHM	PM_{10}	BGI PQ200S	Yes
	PM ₁₀ (collocated)	BGI PQ200S	Yes
Background #1	PM_{10}	BGI PQ200S	Yes
Primary NPL	PM_{10}	BGI PQ200	Yes
	PM ₁₀ (collocated)	BGI PQ200	Yes*

^{*}Failed leak check. See Section 3.0.

Table 1-3
Summary of Meteorological Audit Results

Parameter	Sensor	Within Accuracy Goal
Wind Speed	Met-One 34B	Yes
Wind Direction	Met-One 34B	Yes
Temperature	Campbell Scientific 107	Yes
Precipitation	Hydrological Services TB4	No

Details of the audit are presented in the following sections:

Section 2.0 Audit Methods and Equipment

Section 3.0 Audit Results

Appendix A Audit Data Forms

Appendix B Audit Standards Certifications

Any questions related to this audit or audit report should be addressed to:

Christian A. Kirk
Quality Assurance Officer / Lead Auditor
Air Resource Specialists, Inc.
1901 Sharp Point Drive, Suite E
Fort Collins, Colorado 80525
Telephone: 970-484-7941

Fax: 970-484-3423 E-mail: <u>ckirk@air-resource.com</u>

2.0 AUDIT METHODS

Audit procedures, audit challenge ranges, and acceptance criteria are described below. These ranges and limits conform to EPA's PSD guidelines. Audit results were verbally communicated to the site operator prior to departure from the site. A follow-up e-mail summarizing audit findings was also sent to Alton Coal Development, LLC personnel. Audit details are provided in Appendix A.

Guidance from the following EPA documents was used to establish the audit procedures:

- 40 CFR 58, Appendix A. Quality Assurance Requirements for SLAMS, SPMs, and PSD Air Monitoring
- EPA Quality Assurance Handbook for Air Pollution Measurement Systems:
 - Volume I. A Field Guide to Environmental Quality Assurance
 - Volume II. Ambient Air Quality Monitoring Program
 - Volume IV. Meteorological Measurements
- EPA Meteorological Monitoring Guidance for Regulatory Modeling Applications
- EPA Transfer Standards for Calibration of Air Monitoring Analyzers for Ozone

2.1 PARTICULATE SAMPLERS (FRM PM₁₀)

The filter-based FRM PM $_{10}$ particulate samplers are audited in their normal operating mode. ARS audits the samplers with a BGI deltaCal audit standard which measures flow, temperature, and barometric pressure. Prior to conducting the flow audit, a system leak check is performed in accordance with the manufacturer's specifications. The observed volumetric operational flow and design flow of the sampler are compared to the audit flows measured by the audit standard. Differences between the operational sampler flow and audit flow that are greater than $\pm 10\%$ are considered out of tolerance. Differences between the designated design flow and the audit flow greater than $\pm 10\%$ are considered out of tolerance. In addition to the flow audits, observed ambient temperature, filter temperature, and barometric pressure measurements of the particulate samplers are also audited by comparison to the audit standard. A temperature difference greater than $\pm 2\%$ C and a barometric pressure difference greater than $\pm 10\%$ m Hg are considered out of tolerance. Audit methods and acceptable criteria for the particulate samplers are summarized in Table 2-1.

Table 2-1

Particulate Samplers
Audit Acceptance Criteria

Parameter	Audit Method	Acceptance Criteria	
FRM PM ₁₀	Leak Check	Manufacturer specs	
	Audit flow to actual sampler flow	\leq \pm 4%	
	Design criteria flow to audit flow	≤± 5%	
	Audit temperature to sampler temperature	$\leq \pm 2$ °C	
	Audit temperature to sampler filter temperature	$\leq \pm 2$ °C	
	Audit barometric pressure to sampler pressure	≤±10mm Hg	

Table 2-2
Particulate Samplers
Audit Equipment

References	Manufacturer	Model Number	Serial Number	Expiration Date
FRM Flow	BGI	DeltaCal	1237	1/15/2017

2.2 METEOROLOGICAL PARAMETERS

Meteorological measurement systems are audited in accordance with (and accuracy goals were obtained from) the EPA's *Quality Assurance Handbook for Air Pollution Measurement Systems: Volume IV – Meteorological Measurements*, (March 2008). ARS uses National Institute of Standards and Technologies (NIST) traceable test equipment for all meteorological parameters. All equipment is recertified annually. Audit ranges and acceptable criteria for each parameter are summarized in Table 2-3.

2.2.1 Wind Speed

Wind speed sensors are audited using an R.M. Young model 18802 (high RPM) or 18811 (low RPM) pulsed motor wind speed calibrator. Each sensor is tested at zero and five shaft revolution speeds. The equivalent wind speed is calculated corresponding to the sensor manufacturer's specified values for shaft speed versus wind velocity and compared to readings obtained from the on-site datalogger.

2.2.2 Wind Direction

Wind direction sensor audits include the verification of sensor orientation, linearity, and starting threshold (bearing integrity). The sensor orientation accuracy is verified by a reference. The reference can be an internal reference (a tower-mounted alignment vane) or external (pointing at landmarks from the sensor). Accuracy of the references is verified by the solar azimuth method for the determination of true north. Using a compass and the site latitude and longitude, a computer model outputs the sun's azimuth for that exact time of day. The compass is adjusted to that azimuth, effectively correcting for the compass to the local magnetic declination (which may include local magnetic field disturbances). The sensor orientation accuracy is checked by aligning the wind direction vane to and from each landmark reference, recording sensor responses from the on-site datalogger.

Potentiometer linearity is tested by verifying the change in response between two successive orientations across eight points on a calibrated disc mounted atop the sensor. For example, any two adjacent orientations on the eight-point disc are separated by 45 degrees. The difference in the datalogger response for these two adjacent orientations is compared to this value.

2.2.3 Ambient Temperature

Temperature sensors that are non-immersible are audited by collocation of the audit sensor under ambient conditions utilizing similar methods of sensor aspiration. Collocated comparisons are typically carried out using hourly averages. Audit data are collected by a datalogger provided by the auditor. Temperature sensors that are immersible are audited by comparison to the audit sensor in water baths. The test baths are typically at 0°C, near ambient conditions (or approximately 25°C), and near the full scale of the sensor (typically near 50°C). Data observed on the on-site datalogger are used to assess the accuracy of sensors. Sensor aspirators are inspected for proper function, including fan function and flow direction.

2.2.4 Precipitation

The tipping bucket style precipitation gauges are audited with a volumetric precipitation gauge calibrator by transferring a known amount of water through the gauge orifice at a maximum rate equivalent to 2.0 inches/hour of precipitation. The total values from the on-site datalogger values are compared to the actual introduced volume. The level and cleanliness of the sensor is observed where possible.

Table 2-3

Meteorological Sensors

Audit Ranges and Acceptance Criteria

Parameter	Audit Method	Acceptance Criteria
Wind Speed	Accuracy at five speeds with anemometer drive	≤± 0.2 m/s
	Starting threshold with torque gauge	Manufacturer specs
Wind Direction	Accuracy with compass	≤±5°
	Linearity	≤±5°
	Starting threshold with torque gauge	Manufacturer specs
Ambient Temperature (non-immersible sensor)	Accuracy via collocation in ambient conditions	≤± 0.5 °
Ambient Temperature (immersible sensor)	Accuracy via collocation in three water baths	≤± 0.5°
Precipitation	Accuracy via known volume of water	≤± 10%

Table 2-4
Meteorological Audit Equipment

References	Manufacturer	Model Number	Serial Number	Expiration Date
Wind Speed (high rpm)	R.M. Young	18802	CA03359	4/7/2017
Wind Direction Orientation	Brunton	Transit	5103212072	N/A
Temperature (immersible)	Eutechnics	4400	307635	3/28/2017
Precipitation	Novalynx	260-2595	N/A	N/A

3.0 AUDIT RESULTS

Audit findings and recommendations are discussed below. Detailed audit results are provided in Appendix A.

Performance Audit Results

- The leak check on the collocated sampler at the Primary NPL site failed. After adjustment by the operator, it passed. This leak did not appear to impact flow and, consequently, should not impact data.
- Although the collocated sampler at the Primary CHM site passed all performance audit requirements, the water collection jar on the PM₁₀ inlet was found broken. This could significantly impact the particle size collection and the apparent concentration measured.
- The precipitation gauge was found responding outside of audit requirements. It is recommended that the gauge be challenged again and adjusted, if required.
- The clock for Campbell Scientific CR510 data logger at the meteorological station was set to Mountain Daylight Time. The clock should always be set to Mountain Standard Time.

APPENDIX A AUDIT DATA FORMS



TEMPERATURE / DELTA-TEMPERATURE SYSTEM AUDIT

ABBR.	n/a	CLIE	A TV	ALTON	8 2 2 4 5 7	AUDITOR	C.Kirk	DATE	11/9/201
SITE NAM	E		al Hollow I						
Network ty	pe	Alton	Coal- Coal	l Hollow	I				
			MANUFACT	TURER		MODEL	SERIAL NUMBER	EXPIRATION I	DATE
Temperature I	Reference		Eutechr	nics	,	4400	307635	3/28/201	7
					e',				
2m	Tempera	ture Sen	sor				1		
anufacturer			npbell Scie	entific	P(\$45,035)	List sensors	2		
Model			107			according to			
erial Number		1075	5-14 / WO	#1272		eight on tower,			
					· Tr	om highest to			
						lowest.			
					_				
						Temp. Deltas	1		
						1	1		
					' -				
	N. Artista						2.5		
	100				l –				
					l				
1 3 7 8		-	1						
				100 000 000	- 1				
	119 (1914)								
CALIBRA	TION ACC	EPTANC	E CRITER	IA (<=)	4.00				
Ambient Ter				0.5	SALE, Ne E AN				
	nperature Di	ALCOHOLD AND AND AND	Control of the Contro	0.1					
			-1						
AS FOUND	2m	Temperat	ture			STREET, COMP.			
Bath Temp (°C)	DAS		erence				THE RESERVE AND ADDRESS.	3000	100
0.03	0.16	0.13	PASS	A TO PRODUCE TO A TO					
15.20	15.46	0.26	PASS						
30.15	30.33	0.18	PASS						
MAX ABS Diffe		0.26	PASS						
		0.20	17100	1		A			
		78.00.00.00.00	1						
MAY ADO DIE	ronco								
MAX ABS Diffe	rence								
	rator fan f	unational	1 2m2	Voc	I No	L/ N/A	Fach	vosified assissed to	
Aspir	ator fan f	ипсиопа	Zm?	Yes	☐ No	V N/A		verified against its	Name and Address of the Owner, where the Owner, which is the Owner, which is the Owner, where the Owner, which is the Owner, which
				Yes	No No	N/A		Yes No V N	
				Yes	∐ No	N/A		ure Difference = Up	NAME AND ADDRESS OF THE OWNER, WHEN PERSONS AND ADDRESS O
				Yes	☐ No	□ N/A		Yes No V N	A
NOTES:									
25.1									*
									<u></u>



WIND SPEED SENSOR AUDIT

ABBR.	n/a	CLIENT	ALTON	FIELD SPECIALIST	C.Kirk	DATE	11/9/2016
SITE NAME Coal Hollow Mine				3,			
Netwo	rk type	Alton Coal-	Coal Hollo	₹			

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
Wind Speed Reference	RM Young	18802	CA03359	4/7/2017
Wind Speed Torque Gauge				

Manufacturer and Model	Met One - 034B
Sensor Serial #	E2281
Cups Serial #	N/A

AUDIT CRITERIA (<=)	
Wind Speed Difference (m/s)	0.20
Wind Speed Difference (%)	N/A

Select UNITS	m/s
--------------	-----

		Wind Speed				
Motor Speed (rpm)	Target Speed	DAS	Difference			
0	0.000	0.000	N/A	N/A	N/A	
100	2.943	2.920	-0.02		PASS	
200	5.607	5.630	0.02		PASS	
300	8.270	8.270	0.00	A Company	PASS	
600	16.260	16.340	0.08		PASS	
1800	48.220					

Starting Threshold	TORQUE
Torque <= 0.2 g-cm	
,	

Heater sleeve functional?	Yes	No V N/A

NOTES:		
		20



WIND DIRECTION AUDIT

ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE NAME Coal Hollow Mine					and a second sec		
Netwo	rk type	Alton Coal-	Coal Hollow				

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
Direction Alignment Reference	Brunton	Transit	5103212072	Restaurant Land
Direction Linearity Reference				
Direction Torque Gauge				

Manufacturer & Model	Met One - 034B
Sensor Serial #	E2281
Vane Serial #	N/A

Local Magnetic Declin	ation (degrees)	0.0
Method	n/a	

AUDIT CRITERIA (<=)	
Cross-arm Alignment Error (degrees)	2
Total Align. Diff (degrees)	5
Sensor Linearity (degrees)	5

Mag. Dec. from NOAA (deg/min/sec)	0.00
-----------------------------------	------

Landmarks	Degrees
To left most building/barn to the east	338
From left most building/barn to the east	158
From center of right rock outcrop, saddle	73
To center of right rock outcrop, saddle	253

Reference Alignment Error (degrees) 0.0 PASS

SENSOR	ALIGNMEN	IT I	
Reference	Degrees	DAS	Difference
From the North	0		
From the South	180		
From the East	90		
From the West	270		
Total Alignment	MAX ABS	Diff	

OR

SENSOR A	SENSOR ALIGNMENT			
Landmark	Degrees	DAS	Diffe	rence
ost building/barn to	338	338.0	C	0.0
most building/barn t	158	157.0	- T	1.0
er of right rock outcr	73	73.0		0.0
r of right rock outcro	253	253.0	C	0.0
Total Alignment	MAX ABS	Diff	1.0	PASS

Point	DAS	Difference	
1	DAG	N/A	
2			
3			
4		(all plants)	
5			e de la
6		The state of the	
7			
8	-		
1			
MAX Differe	ence		

Starting Threshold		Starting Threshold		TORQUE
Torque <=	6.5 g-cm			
		Programme and the		

Heater sleeve functional?	Yes No N/A	
NOTES:		



PRECIPITATION SENSOR AUDIT

ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE	NAME	Coal Ho	ollow Mine				
Netwo	rk type	Alton Coal	- Coal Hollow				

1.	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
Precipitation Reference	Novalynx	260-2595	N/A	

Manufacturer	Hydrological Services TB4		
Model			
Serial Number	05-94		

AUDIT CRITERIA (<=)	
Difference from Input Volume (%)	0%

П	Reference Chart			Input Volume (mL)		946
-	Manufacturer	Model	Diameter (in.)	mm/tip	mL/tip	DAS target
ヿ	Met One	385	12	0.254	18.53	12.96
7	RM Young	52202	6.2825	0.100	2.00	47.30
	Climatronics	100097-1-G0-H0	8	0.254	8.24	29.17
T	Climatronics	100508	9.66	0.100	4.73	20.01
X	Hydrological Serv.	TB4	8	0.254	8.24	29.17
4						
- 1						

Conversions				
Value	Units	Value	Units	
1.000	inch	25.40	mm	
25.40	mm	1.000	inch	

		P	recipitation	
Reference (mL)	Target (mm)	DAS (mm)	Difference	
946	29.17	22.61	-22.5%	FAIL

Heater functional?	Yes No N/A

NOTES:		



ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE	IAME	Coal Hol	low Mine		-	4	
Networ	Network type Alton Coal- Coal Hollov						

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
PM Flow Standard #1	BGI	deltaCal	1237	1/15/2017
PM Temperature Standard #1	BGI	deltaCal	1237	1/15/2017
PM Barometric Pressure Standard #1	BGI	deltaCal	1237	1/15/2017

MANUFACTURER	BGI
MODEL	PQ200S
SERIAL NUMBER	962A

SETTINGS						
Total Flow	16.70					

Date and Time correct?
✓ Yes No
If no, time off by:
0 min

Automated LEAK CHECK			
Vacuum Loss Rate	Pass/Fail		
3 cm H2O	PASS		

	FLOW VERIFICATION						
	Reference	Instrument	Actual Diff	Design Diff			
Total Flow	16.95	16.70	-1.5%	1.5%	PASS		

AMBIENT TEMPERATURE SENSOR (°C)					
Reference	Instrument	Difference			
14.0	1/1 2	0.2	DASS		

FILTER TEMPERATURE SENSOR (°C)			
Reference	Instrument	Difference	
12.8	12.2	-0.6	PASS

 PRESS	URE SENSOR (mmHg)	
Reference	Instrument	Difference	
591.5	591.0	-0.5	PASS

AUDIT CRITERIA (<=)	
Actual Flow % Diff	10%
Design Flow % Diff	10%

AUDIT CRITERIA (<=)	3. (25)
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)	
Pressure Difference (mmHg)	10

NOTES:	-				
	, ,				



ABBR.	n/a	CLIENT ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE	IAME	Coal Hollow Mine				
Networ	k type	Alton Coal- Coal Hollov				

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
PM Flow Standard #1	BGI	deltaCal	1237	1/15/2017
PM Temperature Standard #1	BGI	deltaCal	1237	1/15/2017
PM Barometric Pressure Standard #1	BGI	deltaCal	1237	1/15/2017

MANUFACTURER	BGI
MODEL	PQ200S
SERIAL NUMBER	N963B

	SETTINGS	
Total Flow	16.70	

	J
Yes ✓ No	
If no, time off by:	
-4 min	

Automated LEAK	CHECK
Vacuum Loss Rate	Pass/Fail
3 cm H2O	PASS

	FLOW VERIFICATION					
	Reference	Instrument	Actual Diff	Design Diff		
Total Flow	16.68	16.70	0.1%	-0.1%	PASS	

AMBIENT T	EMPERATURE S	ENSOR (°C)	1 1
Reference	Instrument	Difference	
14.7	15.3	0.6	PASS

FILTER TEMPERATURE SENSOR (°C)			
Reference	Instrument	Difference	
15.0	15.3	0.3	PASS

PRESSURE SENSOR (mmHg)					
Reference	Instrument	Difference			
597.5	599.0	1.5	PASS		

AUDIT CRITERIA (<=)
Actual Flow % Diff	10%
Design Flow % Diff	10%

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)	
Pressure Difference (mmHg)	10

NOTES:			



ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE NAME Coal Hollow Mine			1				
Networ	rk type	Alton Coal-	Coal Hollov				

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
PM Flow Standard #1	BGI	deltaCal	1237	1/15/2017
PM Temperature Standard #1	BGI	deltaCal	1237	1/15/2017
PM Barometric Pressure Standard #1	BGI	deltaCal	1237	1/15/2017

MANUFACTURER	BGI
MODEL	PQ200S
SERIAL NUMBER	N964C

ECC 16 FEE	SETTINGS	
Total Flow	16.70	

Date and Time correct?
✓ Yes No
If no, time off by:
0 min

Automated LEAK CHECK			
Vacuum Loss Rate	Pass/Fail		
4 cm H2O	PASS		

		FLOW VER	RIFICATI	ON	
	Reference	Instrument	Actual Diff	Design Diff	
Total Flow	16.78	16.70	-0.5%	0.5%	PASS

Reference

14.5

		7101010	Doorgin Din	2000年10日 - 100 -	7 total 1 10 tr 70 D tr
16.78	16.70	-0.5%	0.5%	PASS	Design Flow % Diff
		ŢI.			7
AMBIEN	T TEMPERA	ATURE S	SENSOR	(°C)	

PASS

Difference

0.1

	FILTER TE	MPERATURE SI	ENSOR (°C)	
1	Reference	Instrument	Difference	
	E07 E	507.0	0.5	DAGG

FILTER TEMPERATURE SENSOR (°C)				
Reference	Instrument	Difference		
597.5	597.0	-0.5	PASS	

Instrument

14.6

PRESSURE SENSOR (mmHg)				
Reference	Instrument	Difference		
14.3	14.4	0.1	PASS	

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)

Temperature Difference (°C)

AUDIT CRITERIA (<=)

10% 10%

AUDIT CRITERIA (<=)	
Pressure Difference (mmHg)	10

NOTES:	broken	jar on	PM10 inte	t



ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE	NAME	Coal Hol	low Mine		:		100
Networ	k type	Alton Coal-	Coal Hollov				

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
PM Flow Standard #1	BGI	deltaCal	1237	1/15/2017
PM Temperature Standard #1	BGI	deltaCal	1237	1/15/2017
PM Barometric Pressure Standard #1	BGI	deltaCal	1237	1/15/2017

MANUFACTURER	BGI
MODEL	PQ200
SERIAL NUMBER	2366D

Total Flow	16.	70	

Date and Time correct?
☐ Yes ✓ No
If no, time off by:
-6 min

Automated LEAK CHECK			
Vacuum Loss Rate	Pass/Fail		
2 cm H2O	PASS		

	FLOW VERIFICATION						
	Reference	Instrument	Actual Diff	Design Diff			
Total Flow	16.75	16.70	-0.3%	0.3%	PASS		

AMBIENT TEMPERATURE SENSOR (°C)				
Reference	Instrument	Difference		
15.6	15.5	-0.1	PASS	

FILTER TE	FILTER TEMPERATURE SENSOR (°C)			
Reference	Instrument	Difference		
16.1	17.3	1.2	PASS	

- 1	PRESSURE SENSOR (mmHg)			
	Reference	Instrument	Difference	-
	596.5	595.0	-1.5	PASS

AUDIT CRITERIA (<=)		
Actual Flow % Diff	10%	
Design Flow % Diff	10%	

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)	
Pressure Difference (mmHg)	10

NOTES:		
		. 1



ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE	SITE NAME Coal		low Mine		2		
Netwo	rk type	Alton Coal-	Coal Hollov				

	MANUFACTURER	MODEL	SERIAL NUMBER	EXPIRATION DATE
PM Flow Standard #1	BGI	deltaCal	1237	1/15/2017
PM Temperature Standard #1	BGI	deltaCal	1237	1/15/2017
PM Barometric Pressure Standard #1	BGI	deltaCal	1237	1/15/2017

MANUFACTURER	BGI
MODEL	PQ200
SERIAL NUMBER	

	SETTINGS	
Total Flow	16.70	

Date and Time correct?
☐ Yes ✓ No
If no, time off by:
-7 min

Automated LEAK CHECK			
Vacuum Loss Rate	Pass/Fail		
	FAIL		

		FLOW VER	RIFICATI	ON	
	Reference	Instrument	Actual Diff	Design Diff	
Total Flow	16.76	16.70	-0.4%	0.4%	PASS

Reference	Instrument	Actual Diff	Design Diff		Actual Flow % Diff	10%
16.76	16.70	-0.4%	0.4%	PASS	Design Flow % Diff	10%
54972 St. 1861 - 64460 75						.7 3

AMBIENT TEMPERATURE SENSOR (°C)					
Reference	Instrument	Difference			
16.0	15.9	-0.1	PASS		

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

AUDIT CRITERIA (<=)

FILTER TEMPERATURE SENSOR (°C)					
Reference	Instrument	Difference			
596.5	597.0	0.5	PASS		

AUDIT CRITERIA (<=)	
Temperature Difference (°C)	2

PRESSURE SENSOR (mmHg)					
Reference	Instrument	Difference			
16.3	17.5	1.2	PASS		

AUDIT CRITERIA (<=)	
Pressure Difference (mmHg)	10

NOTES: Subsequent leak check passed following adjustment by operator. Flow does not appear to be impacted.



SITE INFORMATION

ABBR.	n/a	CLIENT	ALTON	AUDIT	OR	C.Kirk	D	ATE	11/9/2016
SITE N	AME	Coal Hol	low Mine						
NETWOR	K TYPE	Alton Coal-	Coal Hollow						
		1 7	Deg	Min	Sec			Decimal	ı
LATIT	UDE	North	37	23	53.2	CALCULATE->		37.3981	
LONGI	TUDE	West	112	26	43.1			112.4453	1
				CALC	ULATE->				l
ELEVA	TION	Meters	CALCUI	LATE->	Feet				
		Feet			Meters				

Please verify site standards used by the site operator

SITE STANDARDS	MANUFACTURER	MODEL	SERIAL#	Calibration Expiration Date
PM Flow Reference			in .	


NOTES: Lat/Long for met station	4,	
	3	



ABBR.	n/a	CLIENT	ALTON	AUDITOR	C.Kirk	DATE	11/9/2016
SITE N	AME	Coal Ho	llow Mine			.,	
Network	k type	Alton Coal-	Coal Hollov				

	*	MANUFACTURER	MODEL	SERIAL#	Calibration Expiration Date
Ozone Transfer Sta	ndard				
Gas Dilution Transfer Standard					
MFC High Flow Refe	erence		1		
MFC Low Flow Refe	rence			THE RESERVE OF THE SECOND	PROPERTY STATE
Temperature Refer	ence	Eutechnics	4400	307635	3/28/2017
AT/RH Sensor Refe	rence	新子等。其中方面的			
Barometric Pressure R	eference				T
Wind Speed Reference (high rpm)	RM Young	18802	CA03359	4/7/2017
Wind Speed Reference	(low rpm)				
Wind Speed Torque	Gauge				
Wind Direction Alignment	t Reference	Brunton	Transit	5103212072	
Wind Direction Linearity	Reference	的是有多数,这个主要			
Wind Direction Torque	e Gauge	<u>,</u>			提到证据 Bittle
Solar Radiation Refe	erence				
Multiplier	W/m2 / mV			Record Library	
UV Radiation Refer	ence				
Multiplier	W/m2 / mV		3	. 7	
Precipitation Refer	ence				Electric States
Volume 946	mL	Novalynx	260-2595	N/A	
PM Flow Standard	i #1	BGI	deltaCal	1237	1/15/2017
PM Flow Standard	i #2				A SARSAN ASSESSMENT
PM Flow Standard	i #3				
PM Flow Standard	l #4				
PM Temperature Stan	dard #1	BGI	deltaCal	1237	1/15/2017
PM Temperature Stan	THE RESERVE OF THE PERSON NAMED IN COLUMN TWO IS NOT THE PERSON NAMED IN COLUMN TWO IS NAMED IN COLUMN TW				
PM Temperature Stan	1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0 1 0				
PM Temperature Stan	STATE STATE OF THE				
the State of the S	es espera, subsum that	P.C.	1.11.0	1007	445,0012
PM Barometric Pressure S		BGI	deltaCal	1237	1/15/2017
PM Barometric Pressure S	AND THE RESIDENCE OF SHEET STATES				
PM Barometric Pressure S					A CONTRACT TO A CONTRACT OF A
PM Barometric Pressure S	Standard #4				
TEOM MTV Stand	ard				
HiVol Direct Flow Ref	erence				
Orifice					
	eter		No. 1915 Charles of the Control of t		

APPENDIX B AUDIT STANDARDS CERTIFICATIONS



MICRO PRECISION CALIBRATION 22835 INDUSTRIAL PLACE GRASS VALLEY CA 95949 530-268-1860

Certificate of Calibration

Date: Mar 28, 2016 Cert No. 222008122912902

Customer:

AIR RESOURCE SPECIALIST, INC 1901 SHARP POINT DR, STE E FORT COLLINS CO 80525

Work Order #: SAC-70077720

March 28, 2017

 MPC Control #:
 AX7278
 Purchase Order #:
 A30449

 MPC Control #:
 AX7278
 Serial Number:
 307635

 Asset ID:
 N/A
 Department:
 N/A

Gage Type: DIGITAL THERMOMETER Performed By: JAKE WEST

Manufacturer: EUTECHNICS Received Condition: IN TOLERANCE
Model Number: 4400 Returned Condition: IN TOLERANCE

 Size:
 N/A
 Cal. Date:
 March 28, 2016

 Temp/RH:
 70.0°F / 38.0%
 Cal. Interval:
 12 MONTHS

Calibration Notes:

Standards Used to Calibrate Equipment

SPRT W/ CASE

I.D. Description. Model Serial Manufacturer Cal. Due Date Traceability # CR6700 DOUBLE WELL BATH 7013 79006 HART Oct 14, 2016 222008122697272 PRECISION PLATINUM 8167-25 1803221 LEEDS & NORTHRUP 818600 DA8367 Apr 27, 2016 RESISTANCE THERMOMETER

Procedures Used in this Event

Procedure Name Description

MPC-00074 Temperature Devices

Calibrating Technician:

QC Approval:

JAKE WEST

Cple West

BRIAN GOLD

The reported expanded uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for normal distribution corresponds to a coverage probability of approximately 95%. The standard uncertainty of measurement has been determined in accordance with EA's Publication and NIST Technical Note 1297, 1994 Edition. Services rendered comply with ISO 17025:2005, ANSI/NCSL Z540-1, MPC Quality Manual, MPC CSD and with customer purchase order instructions.

Calibration cycles and resulting due dates were submitted/approved by the customer. Any number of factors may cause an instrument to drift out of tolerance before the next scheduled calibration. Recalibration cycles should be based on frequency of use, environmental conditions and customer's established systematic accuracy. The information on this report, pertains only to the instrument identified.

All standards are traceable to SI through the National Institute of Standards and Technology (NIST) and/or recognized national or international standards laboratories. Services rendered include proper manufacturer's service instruction and are warranted for no less than thirty (30) days. This report may not be reproduced in part or in a whole without the prior written approval of the issuing MPC lab.

Page 1 of 1

(CERT, Rev 3)

CALIBRATION PROCEDURE 18802/18811 ANEMOMETER DRIVE

DWG: CP18802(C)

REV: C101107 BY: TJT

PAGE: 2 of 4 DATE: 10/11/07

CHK: JC

W.C. GAS-12

CERTIFICATE OF CALIBRATION AND TESTING

MODEL:

18802 (Comprised of Models 18820A Control Unit & 18830A Motor Assembly)

SERIAL NUMBER:

CA03359

R. M. Young Company certifies that the above equipment was inspected and calibrated prior to shipment in accordance with established manufacturing and testing procedures. Standards established by R.M. Young Company for calibrating the measuring and test equipment used in controlling product quality are traceable to the National Institute of Standards and Technology.

Nominal Motor Rpm	27106D Output Frequency Hz (1)	Calculated Rpm (1)	Indicated Rpm (2)
300	50	300	300
2700	450	2700	2700
5100	850	5100	5100
7500	1250	7500	7500
10,200	1700	10,200	10,200
12,600	2100	12,600	12,600
15,000	2500	15,000	15,000
	Clockwise and Counter	clockwise rotation veri	fied

⁽¹⁾ Measured frequency output of RM Young Model 27106D standard anemometer attached to motor shaft 27106D produces 10 pulses per revolution of the anemometer shaft

☐ New Unit	Service / Repair LNo Calibration Ad	Init justments Required	☐ As Found ☐ As Left
Traceable frequency	meter used in calibration		N: 4863
		Model. <u>-51-07-40</u> OI	v. <u>++000</u>
Date of inspection Inspection Interval	7 Apr 2016 One Year		
		Tested By	1 <u>EC</u>

⁽²⁾ Indicated on the Control Unit LCD display

Indicates out of tolerance

Mesa Labs 10 Park Place Butler, NJ 07405

NIST Traceable Calibration Facility, ISO 9001:2008 Registered



CERTIFICATE OF CALIBRATION - NIST TRACEABILITY

(Refer to instruction manual for further details of calibration)

deltaCal Serial Number:	1237	DATE:	15-Jan-2016

Calibration Operator: P.Pitty

Critical Venturi Flow Meter: Max Uncertainity = 0.346% Serial Number: 1A CEESI NVLAP NIST Data File 07BGI-0001 Serial Number: 2A CEESI NVLAP NIST Data File 07BGI-0003 Serial Number: 5C COX Nist Data File CCAL33222 - 5 C Serial Number: 4A CEESI NVLAP NIST Data File 07BGI-0002

Serial Number: 3A CEESI NVLAP NIST Data File 07BGI-0004

Serial Number: 254881

Room Temperature: Uncertainity=0.071% Room Temperature: 24.8 °C

Brand: Accu-Safe
NIST Traceability No. 516837

vior traccability ive. ore

deltaCal:

Ambient Temperature (set): 24.8 °C Aux (filter) Temperature (set): 24.8 °C

Barometric Pressure ans Absolute Pressure

Vaisala Model PTB330(50-1100) Digital Accuracy: 0.03371% S/N DH0850001

NIST Traceable (Princo Primary Standard Model 453 S/N W12537) Certificate No. P-7485

deltaCal:

Barometric pressure (set): 746 mm of Hg

Results of Venturi Calibration

Flow Rate (Q) vs. Pressure Drop (ΔP). Where: Q=Lpm, ΔP = Cm of H2O

Q= 3.88294 ΔP ^ 0.52106 Overall Uncertainty: 0.35% Q= 3.78777 ΔP ^ 0.54863 Overall Uncertainty: 0.35%

Date Placed In Service \(\lambda \lambda \lambda \lambda \lambda \)
(To be filled in by operator upon receipt)

Recommended Recalibration Date \(\lambda \lambda \lamb

Revised: September 2015 Cal102-01T2 Rev D

To Check a deltaCal 1.5-19.5

VER 4.00P

15-Jan-16 P.Pitty

Hg

-0.02

Average %

			State Company of the		BP= 746	mm of
			any flow rate is .75%. 1237			
	Reading		CV			
	Abs. P Crit. Vent. mm of Hg	Room Temp	Qa Flow Lpm	Qa deltaCal Indicated	% Error	
			¥.			
# 2	145.17 188.07	24.75 24.75	1.658 2.162	1.651 2.155	-0.42 -0.34	
	318.63 402.50	24.75 24.75	3.697 4.684	3.710 4.700	0.34	
	473.53	24.75	5.519	5.550	0.57	
#1	150.00	24.90	6.008	6.000	-0.13	
	259.53	24.90	10.507	10.463	-0.42	
	337.29	24.90	13.702	13.671	-0.22	
	398.26	24.90	16.207	16.180	-0.16	
	476.34	24.90	19.414	19.454	0.21	

To Check a deltaCal

1.5-19.5

VER 3.41P

15-Jan-16 Pre-Recert

BP= 746 mm of Hg

Maximum allowable error at any flow rate is .75%.

Serial No. 1237

	Reading		CV		
	Abs. P		Qa	Qa	
	Crit. Vent.	Room	Flow	deltaCal	
	mm of Hg	Temp	Lpm	Indicated	% Error
# 5	151.5	24.7	4.99	5.01	0.42
	258.5	24.7	8.67	8.60	-0.80
	343.1	24.7	11.58	11.49	-0.77
	455.5	24.7	15.45	15.14	-1.98
	566.3	24.7	19.26	18.94	-1.64

Average % -0.95